

Lafourche Parish Water District No. 1

P.O. BOX 399
LOCKPORT, LOUISIANA 70374

AREA CODE 985
PHONE 532-6924
FAX 532-3867

May 31, 2013


Re: Bids for Material & Supplies

To Whom It May Concern:

Please be informed that Charter Plastics, Inc. PE4710 Pipe has been approved as an approved equal for Item No. 7 for the bid for Materials & Supplies to be bid June 12, 2013 for the Lafourche Parish Water District No. 1.

If you have any questions please contact me.

Yours truly,



Dirk Barrios, General Manager

CIMSCO, INC.
1840 L & A ROAD
METAIRIE, LA 70001

Acknowledged
PTP 6/12/2013

Lafourche Parish Water District No. 1

P.O. BOX 399
LOCKPORT, LOUISIANA 70374

AREA CODE 985
PHONE 532-6924
FAX 532-3667

Date: May 14, 2013

ADDENDA NO. 1 SEALED BID – MATERIALS AND SUPPLIES

FROM: Lafourche Parish Water District No. 1

MESSAGE: The Proposals for Materials and Supplies as prepared by the Lafourche Parish Water District No. 1 is hereby modified, corrected and/or supplemented by this Addenda No. 1 as follows:

Under Section 5, Specifications pages 7 & 8 of 9 the following Item and Description is changed to:

ITEM: DESCRIPTION:

- 7 1" Driscoplex 5100 PE 4710, SDR 9, plastic water service tubing in single 300' coils, as per attached specifications or pre-approved equal.

Plastic Service Tubing to be furnished in copper tube size, SDR-9.

Typical Physical Properties Driscoplex 5100 pipe material

<u>Property</u>	<u>Test Method:</u>	<u>Unit:</u>	<u>Value:</u>
Density	ASTM D 1505	gms/cm ³	0.961
Melt Index	ASTM D 1238	gms/10 min	0.08
Material Cell Classification	ASTM D 3350		445574C
Material Designation	PPI Recommendation		PE 4710
Tensile Strength At Yield	ASTM D638 Type IV	psi	>3500

As manufactured by Chevron Phillips Chemical Company LP, Plano, Texas or equal.

CIMSCO, INC.
1840 L & A ROAD
METAIRIE, LA 70001

*Acknowledged
6/12/2013*

MATERIALS AND SUPPLIES

LAFOURCHE PARISH WATER DISTRICT NO. 1

P. O. BOX 399

LOCKPORT, LA 70374

MAY 2, 2013

**CIMSCO, INC.
1840 L & A ROAD
METAIRIE, LA 70001**

SECTION 1

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGES</u>
1	Table of Contents	1 of 9
2	Advertisement for Bids	2 of 9
3	Instruction to Bidders	3, 4 of 9
4	Louisiana Uniform Public Work Bid Form	5, 6 of 9
5	Specifications	7 – 9 of 9

SECTION 2
ADVERTISEMENT FOR BIDS

The Board of Waterworks Commissioners
Lafourche Parish Water District No. 1
Post Office Box 399
Lockport, LA 70374

Sealed bids will be received by the Board of Waterworks Commissioners of Water District No. 1, Parish of Lafourche, State of Louisiana, until the hour of two o'clock (2:00) p.m., Wednesday, June 12, 2013 at its regular meeting place, the Water Treatment Plant Office, Lockport, Louisiana, and publicly opened immediately, thereafter, for furnishing the following:

- A. Meter Boxes**
- B. Brass Fittings**
- C. Plastic Tubing**
- D. Tapping Saddles**

Electronic bids must be submitted through <http://www.centralbidding.com> prior to the electronic bidding deadline.

Any bid received after the announced closing time will be returned unopened. All bids must be sealed and marked "SEALED BID – MATERIALS AND SUPPLIES".

Copies of detailed specifications and forms may be obtained from Lafourche Parish Water District No. 1, 5753 Highway 308, P.O. Box 399, Lockport, Louisiana 70374.

BOARD OF WATERWORKS COMMISSIONERS

/s/ Sidney Triche

Sidney Triche, President

ATTEST: /s/ Robert Pontif, Jr., Secretary Treasurer

PUBLICATIONS: May 13, 22, and June 6, 2013

CIMSCO, INC.
1840 L & A ROAD
METAIRIE, LA 70001

SECTION 3

INSTRUCTIONS TO BIDDERS

Each bidder shall carefully check all requirements herein set forth in the specifications and shall offer contracts which fully comply with the requirements or shall plainly set forth all points, features, conditions and specifications, etc. wherein his proposal offered does not meet these specifications. Such exceptions, if made, shall be listed by page number in the following blanks and shall be marked in ink on the pages of these specifications and shall be explained in detail in a letter accompanying his bid. Failure to outline such exceptions will require the said bidder to comply with these specifications.

EXCEPTIONS TO SPECIFICATIONS only exception

is that wire will be supplied as 500' or 2500' coils
no 2000' coils are available.

All proposals shall be submitted on the proposal forms hereto attached, which shall remain, bound as originally issued. In the event two or more proposals equal in amount are lowest, the Board of Commissioners of Lafourche Parish Water District No. 1, Lockport, Louisiana, reserves the right to decide to who the contract is to be awarded. Copies of addenda, if any, shall be attached to the bound volume submitted.

Bidders shall furnish all information required herein by filling in all the blanks in the submitted copy of these specifications. Each bidder shall indicate in his proposal, in the space provided for that purpose, delivery times from date of order.

The Lafourche Parish Water District No. 1 is exempted from the payment of all State and Local Sales Tax in accordance with House Bill 1139 (Act 1029) effective September 1, 1991. The unit price bid on each item shall be the amount required to furnish the units FOB to the Lafourche Parish Water District No. 1 warehouse.

At any time prior to the scheduled closing time for receipt of proposals, any bidder may withdraw his proposal. After scheduled closing time for the receipt of proposals or before award of the contract, no bidder will be permitted to withdraw his proposal, unless said award is delayed for a period exceeding thirty (30) days or the date of the next regular meeting of the Board whichever is longer. Negligence on the part of the bidder in preparing the bid confers no rights for the withdrawal of the proposal after it has been opened.

The quantities shown are estimated quantities based upon the use of the Water District during the past year. The District reserves the right to either increase or decrease the quantities to fulfill its needs. The Bidder declares that he understands that if the quantities of any of these items are increased the undersigned propose to furnish these units at the unit price set herein, and should the quantities be decreased he also understands that payment will be made on the actual quantities furnished at the unit price bid and will make no claim for anticipated profits for any decrease in the above mentioned items.

Delivery of all items of these specifications is to be made to the Lafourche Parish Water District No. 1 Warehouse, 5753 Highway 308, Lockport, Louisiana, in quantities as directed upon execution of contract and when purchase order is issued.

Bidders may submit bids on all or individual items. Items will be awarded on individual bases. Proposals may be delivered in person or may be mailed to reach the Purchaser prior to the opening of bids. Proposals shall be enclosed in sealed envelopes, addressed to the Purchaser and marked, **" SEALED BID – MATERIALS AND SUPPLIES "**.

NOTE: ANY ITEM THAT DOES NOT MEET SPECIFICATION MUST BE APPROVED BY DISTRICT A MINIMUM OF 10 DAYS PRIOR TO BID OPENING.

THE SUPPLIER WILL COMPLY WITH THE CURRENT LOUISIANA LAW FOR "NO - LEAD" BRASS.

**MSCO, INC.
1640 L & A ROAD
METAIRIE, LA 70001**

SECTION 4

LOUISIANA UNIFORM PUBLIC WORK BID FORM UNIT PRICE FORM

TO: Lafourche Parish Water District No. 1
P. O. Box 399
Lockport, LA 70374

BID FOR: Materials and Supplies

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# meter box			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
1	900	Per each	\$ 112.39	\$ 101,151.00

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# meter box locking lid with 2" hole			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
2	2,500	Per each	\$ 11.09	\$ 27,725.00

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# 1" corporation stop, compression or pack joint			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
3	500	Per each	\$ 33.07	\$ 16,535.00

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# 3/4" expander wheel			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
4	750	Per each	\$ 13.39	\$ 10,042.50

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# upper sections meter box			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
5	200	Per each	\$ 23.58	\$ 4716.00

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# meter box locking lid with 2" hole			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
6	50	Per each	N/B	N/B

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# 1" plastic water service tubing			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
7	20,000	Per foot	.78¢	\$ 15,600.00

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt.# 8" bronze tapping saddles/stainless steel or bronze strap			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
8	350	Per each	\$ 66.78	\$ 23,373.00

LOUISIANA UNIFORM PUBLIC WORK BID FORM
UNIT PRICE FORM

TO: Lafourche Parish Water District No. 1
P. O. Box 399
Lockport, LA 70374

BID FOR: Materials and Supplies

UNIT PRICES: This form shall be used for any and all work required by the Bidding Documents and described as unit prices. Amounts shall be stated in figures and only in figures.

DESCRIPTION:	<input type="checkbox"/> Base Bid or <input type="checkbox"/> Alt. # <u>12 gauge dark blue tracing wire</u>			
REF. NO.	QUANTITY:	UNIT OF MEASURE:	UNIT PRICE	UNIT PRICE EXTENSION (Quantity times Unit Price)
9	15,000	Per foot	<u>0.15</u>	<u>\$ 2250.00</u>

Wording for "DESCRIPTION" is to be provided by the Owner.

All quantities are estimated. The contractor will be paid based upon actual quantities as verified by the Owner

AUTHORITY NOTE: Promulgated in accordance with R.S. 38:2212.

HISTORICAL NOTE: Promulgated by the Office of the Governor, Division of Administration, Office of Facility Planning and Control, LR 35:1522 (August 2009).

The undersigned bidder hereby declares and represents that she/he; a) has carefully examined and understands the Bidding Documents, b) has not received, relied on, or based his bid on any verbal instructions contrary to the Bidding Documents or any addenda, c) is familiar with and hereby proposes to provide materials, all in strict accordance with the Bidding Documents prepared by: Lafourche Parish Water District No. 1 and dated: June 12, 2013.

Bidders must acknowledge all addenda. The Bidder acknowledges receipt of the following **ADDENDA:** (Enter the number the Designer has assigned to each of the addenda that the Bidder is acknowledging) Addendum # 1 acknowledged PER IT

TERMS — % — DAYS OR Net 30

PROPOSAL SUBMITTED BY: CIMSCO, INC.
(Company Name)

ADDRESS: 1840 L & A Rd.

SIGNATURE OF REPRESENTATIVE: Paul E. Riviere III

REPRESENTATIVE: Paul E. Riviere III

TITLE: V-P

PHONE NO. 504-835-7319 DATE: 6/12/2013

SECTION 5

SPECIFICATIONS

<u>ITEM:</u>	<u>DESCRIPTION:</u>
1	Meter Box: 1" angle inlet, Ford YL-241-243, Mueller 1452 J or McDonald 75-208-LC2G-43, packed in individual cardboard box or pre-approved equal.
2	Meter Box Locking Lid with 2" Hole: YL-T Ford Meter, yoke box locking lid with 2" hole for 5/8" x 3/4" meter or pre-approved equal. (For Badger Orion Transmitter.) Will furnish a cover for pattern.
3	Ford F1000, Mueller H15008, or McDonald 4701-22 1" corporation stops, compression or pack joint or pre-approved equal.
4	3/4" Expander Wheel: Ford EC-23 Expansion Connection, Mueller H-14234 Expansion Hand Wheel or McDonald 14-2EHG Yoke Expander Wheel or pre-approved equal.
5	Ford YUC-7 upper sections meter box, or pre-approved equal.
6	Meter Box Locking Lid with 2" Hole: 75L43 Locking Meter Box 1" Round Lids with 2" holes or approved equal. (For Badger Orion Transmitter) Will furnish a cover for pattern.
7	1" Driscopipe 5100, PE 3408, SDR 9, plastic water service tubing in single 300' coils, as per attached specifications or pre-approved equal.

Plastic Service Tubing to be furnished in copper tube size, SDR-9.

Typical Physical Properties Driscopipe 5100 pipe material

<u>Property</u>	<u>Test Method:</u>	<u>Unit:</u>	<u>Value:</u>
Density	ASTM D 1505	gms/cc	0.957
Melt Flow	ASTM D 1238(cond. F)	gms/10 min	1.5

<u>Property</u>	<u>Test Method:</u>	<u>Unit:</u>	<u>Value:</u>
Material Cell Classification	ASTM D 3350		355434C
Material Designation	PPI Recommendation		PE 3408
Tensile Strength, Ultimate	ASM D 638 (2"/min.)	psi	5000

As manufactured by Phillips Products Co., Inc., Dallas, Texas or equal.

ITEM:

DESCRIPTION:

8

Romac Bronze Tapping Saddles/Stainless Steel Strap -101BS x 9.62 x 1" cc Thread - O.D. Range 8.63-9.62, Mueller Bronze Tapping Saddle/ Stainless Steel Strap – BR 1 S x 1" cc Thread – O. D. Range 8.99 – 9.67 or pre-approved equal.
Romac Bronze Tapping Saddles/Bronze Strap -101B x 9.62 x 1" cc Thread - O.D. Range 8.63-9.62 or approved equal.

Romac

Saddle Castings: The saddle body is cast from 85-5-5-5 waterworks bronze in accordance with AWWA C-800 and ASTM B 62.

Strap: Type 304 (18-8) Heavy gauge Stainless Steel per ASTM A 240, 2" wide.

Bolts, Nuts: 5/8" UNC roll thread Type 304 (18-8) Stainless Steel bolts per ASTM A 479. All welds fully passivated for enhanced corrosion resistance.

Washer-Nuts: Flat, type 304 (18-8) heavy gauge Stainless Steel.

Gaskets: Gaskets are made from Nitrile Butadiene Rubber (NBR) compounded for water service in accordance with ASTM D 2000 MBC 610. (101BS)

OR

Mueller

Saddle Castings: The saddle body is cast from 85-5-5-5 waterworks bronze in accordance with AWWA C-800 and ASTM B 62. NSF 61 certified.

Strap: 304L Stainless Steel 2" wide and shall be fully passivated.

Bolts, Nuts: 5/8" 304L Stainless Steel bolts with Teflon coated rolled threads and shall be fully passivated.

Washer-Nuts: 304L Stainless Steel and shall be fully passivated.

Gaskets: Nitrile o-ring gasket cemented in and confined in a retaining groove. (BR 1 S)

OR

Romac

Saddle Castings: The saddle body is cast from 85-5-5-5 waterworks bronze in accordance with AWWA C-800 and ASTM B 62.

Strap: Silicon bronze per ASTM B 96, .093" thick X 2" wide to spread out clamping forces on the pipe. GTAW welds using silicon bronze filler rod. Chemically treated for improved corrosion resistance.

Bolts: Silicon bronze per ASTM B 98, 5/8" National Coarse roll thread

Washer-Nuts: Cast from 85-5-5-5 waterworks bronze in accordance with AWWA C-800 and ASTM B 62.

Gaskets: Gaskets are made from Nitrile Butadiene Rubber (NBR) compounded for water service in accordance with ASTM D 2000 MBC 610-90. (101B)

ITEM:

9

DESCRIPTION:

12 Gauge Dark Blue Tracing Wire, 12 THHN 600V – VW – 1 in 2000' rolls or pre-approved equal.

CIMSCO, INC.
1840 L & A ROAD
METAIRIE, LA 70001