

NEW AIRCRAFT HANGARS

MERIDIAN AIRPORT AUTHORITY
MERIDIAN, MISSISSIPPI

ADDENDUM NO. 1

TO: ALL BIDDERS ON THE ABOVE REFERENCED PROJECT
FROM: Richmond L. Alexander, P.E.
DATE: October 8, 2024
SUBJECT: ADDENDUM NO. 1


Addition to Contract Documents for the referenced project is as follows:

1. **INSERT:** Legal advertisement for project that was inadvertently omitted from the contract documents. This legal advertisement goes behind the Table of Contents and before Page IB-1.
2. **CLARIFICATION:** Roof System for hangars shall be Standing Seam
3. **CLARIFICATION:** Wind and Collateral loads shall be per IBC 21;
4. **CLARIFICATION:** Contractor shall provide 3-foot undercut below the building slab at **Site B**. Borrow material shall classify as a Sandy Clay (CL) or Clayey Sand (SC) with a Plasticity Index between 6-22 and a liquid limit less than 45

Undercut shall be included as part of the Site B Hangar Foundation and shall be paid for under the lump sum item S-301-02. Not a Separate Pay Item

5. **CLARIFICATION:** Site A Fire Wall shall meet requirements of UL U415, multiple options are acceptable. Please see the attachment to this Addendum.
6. **CLARIFICATION:** Site B bathroom wall finish shall be painted sheet rock with owner selecting the paint color
7. **CLARIFICATION:** Plumbing fixtures and door and hardware schedule were inadvertently left off plans. Fixture, door and hardware schedules are attached to this addendum.

Submitted By:



Richmond L. Alexander, P.E.
Project Engineer
Date: October 8, 2024

Acknowledge by:



Contractor's Signature

October 8, 2024
Date

THIS ADDENDUM SHALL BE SIGNED, DATED AND SUBMITTED WITH BID DOCUMENTS. FAILURE TO PROPERLY ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND ATTACH IT TO BID DOCUMENTS SHALL BE GROUNDS FOR REJECTING PROPOSAL.